

Lee County Utilities Authority Lee County Water System 2016 How Safe is Our Water?

Lee County Utilities Authority is proud of the fine drinking water it provides. This annual quality report shows the sources of our water, lists the results of our test, and contains much important information about water and health. Lee County Utilities Authority will notify you immediately if there is any reason for concern about our water. We are happy to show you how we have surpassed water quality standards. The Authority contracts with the Georgia Environment Protection Division (EPD), Drinking Water Program, for laboratory and related services consistent with the Authority's need to comply with the requirements of the National Drinking Water Regulations. (Copies of contracts are available for viewing in the Utilities Authority Office located at 905 US Highway 19 South, Leesburg, Georgia).

Is our water safe to drink? Absolutely.

More information is available on the World Wide Web at <http://www.waterdata.com>. The Department of Natural Resources, Environmental Protection Division completed an inspection of the referenced system in June 2016. No major violations were found during this inspection. The Authority contracts with the State of Georgia Environmental Protection Division/ Department of Natural Resources to test the Authority's water samples.

Water Service

The Authority draws its water from three different aquifers. They are Clayton, Upper Floridian and Lower Floridian. The Authority used (10) ten wells located throughout the southern end of the county and supplies an average of 2.5 million gallons of water per day to our customers. A Source-Water Assessment has been performed for our area to provide baseline data about the quality origins of contaminants within our areas. This assessment indicates the susceptibility of our water system to such contaminants. To complete your understanding of our water supply, request a copy from the Georgia Environmental Protection Division.

How to Read This Table

The table below lists all of the drinking water contaminants that we detected during calendar year 2016. The presence of contaminants does not necessarily indicate that water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done during calendar year 2016. The EPD of Georgia Dept. of Natural Resources requires us to monitor for certain contaminants less than once per year because these contaminants do not change frequently. In the event a contaminant exceeds a trigger level more sampling and analysis will be performed to ensure safety and quality.

Terms & Abbreviations used below:

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below, which there is no known or expected risk to health. MCLG allow for a margin of safety.

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Action Level (AL): The concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.

N/A: Not applicable

ND: Not detectable at testing limit

ppb: parts per billion or micrograms per liter

ppm: parts per million or milligrams per liter

TT: Treatment Technique

Contaminant	MCLG	MCL	Major Source	Violation
Total Coliform (# Positive Samples)	0	1	Naturally present in the environment.	NO
Total Organic Carbon (TOC)	TT	TT	Composed primarily of non-specific humic materials	NO
Inorganic				
Lead (ppb)	0	AL=15	Corrosion of piping system: erosion of natural deposits	NO
Copper (ppm)	1.3	AL=1.3	Water additive to control microbes	NO
Chlorine (ppm)	4	4		NO
Unregulated Contaminants				
Nitrates (ppm)	10	10	Found in Fertilizers	NO
TTHM (Total Trihalomethanes)	0	80 (Annual Avg.)	By-product of organics in drinking water and the chlorine disinfectant.	NO
HAA5 (Haloacetic Acids)	0	60 (Annual Avg.)	By-product of drinking water chlorination	NO
cis-1,2- Dichloroethylene	70	70	Discharge from industrial chemical factories	NO

Regulated and Unregulated Contaminants

The Environmental Protection Division of Georgia tests for Radon during water surveys. The Authority is contracted with the Environmental Protection Division of Georgia to analysis its water samples for regulated and unregulated contaminants.

Required Additional Health Information

To ensure that tap water is safe to drink, EPD establishes limits on the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water.

Drinking water, including bottled water may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (tap and bottled) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or human activity. Contaminants that may be present in source water include:

- (A) Microbial contaminants: such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operation, and wildlife
- (B) Inorganic contaminants, such as sales and metal, which can be naturally-occurring or results from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming
- (C) Pesticides and herbicides, which may come from a variety of sources such as stormwater runoff, and residential uses.
- (D) Organic chemical contaminants, including synthetic and volatile organics, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems
- (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink the EPA establishes regulations, which limits the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water and must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than others in the general population. Immune-compromised persons such as: individuals with cancer undergoing chemotherapy, individuals who have undergone organ transplants, individuals with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These individuals should seek advice about drinking water from their health care providers. The EPA and CDC provide guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and are available from the Safe Drinking Water Hotline (800-426-4791).

**National Primary Drinking Water Regulation Compliance
Other Monitoring**

In addition to the referenced testing, staff members are required to monitor the chlorine residual in the finished water daily. If you are interested in a more detailed report, contact Chris Boswell, General Manager (229) 759-6056.

We will be happy to answer any questions about Lee County Utilities Authority and our water quality. Call Tricia Mills at 229-759-6056. Water Quality Data for community water systems throughout the United States is available at www.waterdata.com.

Lee County Utilities Authority Palmyra Water System 2016 How Safe is Our Water?

Lee County Utilities Authority is proud of the fine drinking water it provides. This annual quality report shows the sources of our water, lists the results of our test, and contains much important information about water and health. Lee County Utilities Authority will notify you immediately if there is any reason for concern about our water. We are happy to show you how we have surpassed water quality standards. The Authority contracts with the Georgia Environment Protection Division (EPD), Drinking Water Program, for laboratory and related services consistent with the Authority's need to comply with the requirements of the National Drinking Water Regulations. (Copies of contracts are available for viewing in the Utilities Authority Office located at 905 US Highway 19 South, Leesburg, Georgia).

Is our water safe to drink? Absolutely. Lee County Utilities Authority has never had a violation of contaminant levels or other water quality regulations.

More information is available on the World Wide Web at <http://www.waterdata.com>. An E.P.D., inspection revealed no major violation in 2016. The Authority contracts with the State of Georgia Environmental Protection Division/ Department of Natural Resources to test the Authority's water samples.

Water Service

The Authority draws its water from one aquifer. The aquifer is the Upper Floridian. A Source-Water Assessment has been performed for our area to provide baseline data about the quality origins of contaminants within our areas. This assessment indicates the susceptibility of our water system to such contaminants. To complete your understanding of our water supply, request a copy from the Georgia Environmental Protection Division.

How to Read This Table

The table below lists all of the drinking water contaminants that we detected during calendar year 2016. The presence of contaminants does not necessarily indicate that water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done during calendar year 2016. The E.P.D. of Georgia Dept. of Natural Resources requires us to monitor for certain contaminants less than once per year because these contaminants do not change frequently. In the event a contaminant exceeds a trigger level more sampling and analysis will be performed to ensure safety and quality.

Terms & Abbreviations used below:

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below, which there is no known or expected risk to health. MCLG allow for a margin of safety.

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Action Level (AL): The concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.

N/A: Not applicable

ND: Not detectable at testing limit

ppb: parts per billion or micrograms per liter

ppm: parts per million or milligrams per liter

Contaminant	MCLG	MCL	Major Source	Violation
Total Coliform (# Positive Samples)	0	1	Naturally present in the environment.	NO
Total Organic Carbon (TOC)	TT	TT	Composed primarily of non-specific humic materials	NO
Inorganic				
Lead (ppb)	0	AL=15	Corrosion of piping system: erosion of natural deposits Water additive to control microbes	NO
Copper (ppm)	1.3	AL=1.3		NO
	4	4		NO
Chlorine				
Unregulated Contaminants				
Nitrates (ppm)	10	10	Found in Fertilizers	NO
TTHM (Total Trihalomethanes)	0	80 (Annual Avg.)	By-product of organics in drinking water and the chlorine disinfectant.	NO
HAA5 (Haloacetic Acids)	0	60 (Annual Avg.)	By-product of drinking water chlorination	NO
cis-1,2-Dichloroethylene	70	70	Discharge from industrial chemical factories	NO

Regulated and Unregulated Contaminants

Although we ran many tests, no contaminants were found. The Environmental Protection Division of Georgia tests for Radon during water surveys.

Required Additional Health Information

To ensure that tap water is safe to drink, EPD establishes limits on the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water.

Drinking water, including bottled water may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and

potential health effects can be obtained by calling environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (tap and bottled) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or human activity. Contaminants that may be present in source water include:

- (A) Microbial contaminants: such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operation, and wildlife
- (B) Inorganic contaminants, such as sales and metal, which can be naturally-occurring or results from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming
- (C) Pesticides and herbicides, which may come from a variety of sources such as stormwater runoff, and residential uses.
- (D) Organic chemical contaminants, including synthetic and volatile organics, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems
- (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink the EPA establishes regulations, which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water and must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than others in the general population. Immune-compromised persons such as: individuals with cancer undergoing chemotherapy, individuals who have undergone organ transplants, individuals with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections; these individuals should seek advice about drinking water from their health care providers. The EPA and CDC provide guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and are available from the Safe Drinking Water Hotline (800-426-4791).

National Primary Drinking Water Regulation Compliance

Other Monitoring

In addition to the referenced testing, staff members are required to monitor the chlorine residual in the finished water daily. If you are interested in a more detailed report, contact Chris Boswell, General Manager at (229) 759-6056.

We will be happy to answer any questions about Lee County Utilities Authority and our water quality. Call Tricia Mills at 229-759-6056. Water Quality Data for community water systems throughout the United States is available at www.waterdata.com.

Lee County Board of Commissioners Lee County Criminal Justice Center 2016 How Safe is Our Water?

Lee County Utilities Authority is proud of the fine drinking water it provides. This annual quality report shows the sources of our water, lists the results of our test, and contains much important information about water and health. Lee County Utilities Authority will notify you immediately if there is any reason for concern about our water. We are happy to show you how we have surpassed water quality standards. The Authority contracts with the Georgia Environment Protection Division (EPD), Drinking Water Program, for laboratory and related services consistent with the Authority's need to comply with the requirements of the National Drinking Water Regulations. (Copies of contracts are available for viewing in the Utilities Authority Office located at 905 US Highway 19 South, Leesburg, Georgia).

Is our water safe to drink? Absolutely. Lee County Utilities Authority has never had a violation of contaminant levels or other water quality regulations.

More information is available on the World Wide Web at <http://www.waterdata.com> The Authority contracts with the State of Georgia Environmental Protection Division/ Department of Natural Resources to test the Authority's water samples.

Water Service

The Authority draws its water from two different aquifers. They are the Upper Floridian and Lower Floridian. A Source-Water Assessment has been performed for our area to provide baseline data about the quality origins of contaminants within our areas. This assessment indicates the susceptibility of our water system to such contaminants. To complete your understanding of our water supply, request a copy from the Georgia Environmental Protection Division.

How to Read This Table

The table below lists all of the drinking water contaminants that we detected during calendar year 2016. The presence of contaminants does not necessarily indicate that water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done during calendar year 2016. The E.P.D. of GA. Dept. of Natural Resources of the State requires us to monitor for certain contaminants less than once per year because these contaminants do not change frequently. In the event contaminant exceeds a trigger level more sampling and analysis will be performed to ensure safety and quality.

Terms & Abbreviations used below:

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below, which there is no known or expected risk to health. MCLG allow for a margin of safety.

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Action Level (AL): The concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.

N/A: Not applicable

ND: Not detectable at testing limit

ppb: parts per billion or micrograms per liter

ppm: parts per million or milligrams per liter

Contaminant	MCLG	MCL	Major Source	Violation
Total Coliform (# Positive Samples)	0	1	Naturally present in the environment.	NO
Total Organic Carbon (TOC)	TT	TT	Composed primarily of non-specific humic materials	NO
Inorganic				
Lead (ppb)	0	AL=15	Corrosion of piping system: erosion of natural deposits	NO
Copper (ppm)	1.3	AL=1.3	Water additive to control microbes	NO
Chlorine (ppm)	4	4		NO
Unregulated Contaminants				
Nitrates (ppm)	10	10	Found in Fertilizers	NO
TTHM (Total Trihalomethanes)	0	80 (Annual Avg.)	By-product of organics in drinking water and the chlorine disinfectant.	NO
HAA5 (Haloacetic Acids)	0	60 (Annual Avg.)	By-product of drinking water chlorination	NO
cis-1,2- Dichloroethylene	70	70	Discharge from industrial chemical factories	NO

Regulated and Unregulated Contaminants

Although we ran many tests, no contaminants were found. The Environmental Protection Division of Georgia tests for Radon during water surveys.

Required Additional Health Information

To ensure that tap water is safe to drink, EPD establishes limits on the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water.

Drinking water, including bottled water may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (tap and bottled) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring

minerals and radioactive material, and can pick up substances resulting from the presence of animals or human activity. Contaminants that may be present in source water include:

- (A) Microbial contaminants: such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operation, and wildlife
- (B) Inorganic contaminants, such as sales and metal, which can be naturally-occurring or results from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming
- (C) Pesticides and herbicides, which may come from a variety of sources such as stormwater runoff, and residential uses.
- (D) Organic chemical contaminants, including synthetic and volatile organics, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems
- (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink the EPA establishes regulations, which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water and must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than others in the general population. Immune-compromised persons such as: individuals with cancer undergoing chemotherapy, individuals who have undergone organ transplants, individuals with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections; these individuals should seek advice about drinking water from their health care providers. The EPA and CDC provide guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and are available from the Safe Drinking Water Hotline (800-426-4791).

National Primary Drinking Water Regulation Compliance

Other Monitoring

In addition to the referenced testing, staff members are required to monitor the chlorine residual in the finished water daily. If you are interested in a more detailed report, contact Chris Boswell, General Manager (229) 759-6056.

We will be happy to answer any questions about Lee County Utilities Authority and our water quality please contact Tricia Mills at (229) 759-6056. Water Quality Data for community water systems throughout the United States is available at www.waterdata.com.

LEE COUNTY UTILITIES AUTHORITY, GA1770068

Drinking Water Branch

Chem/Rad Sample Results

Water System No. :	GA1770068	Federal Type :	C
Water System Name :	LEE COUNTY UTILITIES AUTHORITY	State Type :	C
Principal County Served :	LEE	Primary Source :	GW
Status :	A	Activity Date :	02-06-1996
Lab Sample No. :	AJ15033	Collection Date :	06-22-2016

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1038	NITRATE-NITRITE	mll	N		0	0.52 MG/L	01-01-2016	12-31-2016

Drinking Water Branch

Chem/Rad Sample Results

Water System No. :	GA1770068	Federal Type :	C
Water System Name :	LEE COUNTY UTILITIES AUTHORITY	State Type :	C
Principal County Served :	LEE	Primary Source :	GW
Status :	A	Activity Date :	02-06-1996
Lab Sample No. :	AJ15029	Collection Date :	06-22-2016

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1038	NITRATE-NITRITE	mll	N		0	1.3 MG/L	01-01-2016	12-31-2016

Drinking Water Branch

Chem/Rad Sample Results

Water System No. :	GA1770068	Federal Type :	C
Water System Name :	LEE COUNTY UTILITIES AUTHORITY	State Type :	C
Principal County Served :	LEE	Primary Source :	GW
Status :	A	Activity Date :	02-06-1996
Lab Sample No. :	AJ22818	Collection Date :	08-16-2016

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1012	RESIDUAL CHLORINE	mll	N		0	1.0 MG/L		
1996	TEMPERATURE (CENTIGRADE)	mll	N		0	29.00 C		
2450	MONOCHLOROACETIC ACID	mll	Y	MRL	2 UG/L			
2451	DICHLOROACETIC ACID	mll	Y	MRL	1 UG/L			
2452	TRICHLOROACETIC ACID	mll	Y	MRL	1 UG/L			
2453	MONOBROMOACETIC ACID	mll	Y	MRL	1 UG/L			
2454	DIBROMOACETIC ACID	mll	Y	MRL	1 UG/L			
2456	TOTAL HALOACETIC ACIDS (HAAS)	mll	Y	MRL	6 UG/L	0	01-01-2016	12-31-2016
2941	CHLOROFORM	mll	N		0	2.6 UG/L		
2942	BROMOFORM	mll	Y	MRL	1 UG/L			
2943	BROMODICHLOROMETHANE	mll	N		0	1.6 UG/L		
2944	DIBROMOCHLOROMETHANE	mll	N		0	1.0 UG/L		
2950	TTHM	mll	N		0	5.2 UG/L	01-01-2016	12-31-2016

Drinking Water Branch

Chem/Rad Sample Results

Water System No. :	GA1770068	Federal Type :	C
Water System Name :	LEE COUNTY UTILITIES AUTHORITY	State Type :	C
Principal County Served :	LEE	Primary Source :	GW
Status :	A	Activity Date :	02-06-1996
Lab Sample No. :	AJ22817	Collection Date :	08-16-2016

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1012	RESIDUAL CHLORINE	mll	N		0	1.2 MG/L		
1996	TEMPERATURE (CENTIGRADE)	mll	N		0	30.00 C		
2450	MONOCHLOROACETIC ACID	mll	Y	MRL	2 UG/L			
2451	DICHLOROACETIC ACID	mll	Y	MRL	1 UG/L			
2452	TRICHLOROACETIC ACID	mll	Y	MRL	1 UG/L			
2453	MONOBROMOACETIC ACID	mll	Y	MRL	1 UG/L			
2454	DIBROMOACETIC ACID	mll	Y	MRL	1 UG/L			
2456	TOTAL HALOACETIC ACIDS (HAA5)	mll	Y	MRL	6 UG/L	0	01-01-2016	12-31-2016
2941	CHLOROFORM	mll	N		0	2.7 UG/L		
2942	BROMOFORM	mll	Y	MRL	1 UG/L			
2943	BROMODICHLOROMETHANE	mll	N		0	2.3 UG/L		
2944	DIBROMOCHLOROMETHANE	mll	N		0	1.6 UG/L		
2950	TTHM	mll	N		0	6.6 UG/L	01-01-2016	12-31-2016

PALMYRA MHP, GA1770017

Drinking Water Branch

Chem/Rad Sample Results

Water System No. :	GA1770017	Federal Type :	C
Water System Name :	PALMYRA MOBILE HOME PARK	State Type :	C
Principal County Served :	LEE	Primary Source :	GW
Status :	A	Activity Date :	03-12-1980
Lab Sample No. :	AJ15028	Collection Date :	06-22-2016

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1038	NITRATE-NITRITE	mll	N		0	1.2 MG/L	01-01-2016	12-31-2016

LEE CO. CRIMINAL JUSTICE CENTER, GA1770074

Chem/Rad Sample Results

Water System No. :	GA1770074	Federal Type :	C
Water System Name :	LEE CO. CRIMINAL JUSTICE CENTER	State Type :	C
Principal County Served :	LEE	Primary Source :	GW
Status :	A	Activity Date :	01-31-2000
Lab Sample No. :	AJ26208	Collection Date :	09-08-2016

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
2030	P-ISOPROPYLTOLUENE	null	Y	MRL	5 UG/L			
2210	CHLOROMETHANE	null	Y	MRL	5 UG/L			
2212	DICHLORODIFLUOROMETHANE	null	Y	MRL	5 UG/L			
2214	BROMOMETHANE	null	Y	MRL	5 UG/L			
2216	CHLOROETHANE	null	Y	MRL	5 UG/L			
2218	TRICHLOROFLUOROMETHANE	null	Y	MRL	5 UG/L			
2224	TRANS-1,3-DICHLOROPROPENE	null	Y	MRL	5 UG/L			
2228	CIS-1,3-DICHLOROPROPENE	null	Y	MRL	5 UG/L			
2246	HEXACHLOROBUTADIENE	null	Y	MRL	5 UG/L			
2248	NAPHTHALENE	null	Y	MRL	5 UG/L			
2251	METHYL TERT-BUTYL ETHER	null	Y	MRL	5 UG/L			
2378	1,2,4-TRICHLOROBENZENE	null	Y	MRL	5 UG/L		01-01-2014	12-31-2016
2380	CIS-1,2-DICHLOROETHYLENE	null	Y	MRL	5 UG/L		01-01-2014	12-31-2016
2408	DIBROMOMETHANE	null	Y	MRL	5 UG/L			
2410	1,1-DICHLOROPROPENE	null	Y	MRL	5 UG/L			
2412	1,3-DICHLOROPROPANE	null	Y	MRL	5 UG/L			
2414	1,2,3-TRICHLOROPROPANE	null	Y	MRL	5 UG/L			
2416	2,2-DICHLOROPROPANE	null	Y	MRL	5 UG/L			
2418	1,2,4-TRIMETHYLBENZENE	null	Y	MRL	5 UG/L			
2420	1,2,3-TRICHLOROBENZENE	null	Y	MRL	5 UG/L			
2422	N-BUTYLBENZENE	null	Y	MRL	5 UG/L			
2424	1,3,5-TRIMETHYLBENZENE	null	Y	MRL	5 UG/L			
2426	TERT-BUTYLBENZENE	null	Y	MRL	5 UG/L			
2428	SEC-BUTYLBENZENE	null	Y	MRL	5 UG/L			
2430	BROMOCHLOROMETHANE	null	Y	MRL	5 UG/L			
2931	1,2-DIBROMO-3-CHLOROPROPANE	null	Y	MRL	5 UG/L		01-01-2014	12-31-2016
2941	CHLOROFORM	null	N		0	79.00 UG/L		
2942	BROMOFORM	null	Y	MRL	5 UG/L			
2943	BROMODICHLOROMETHANE	null	N		0	9.6 UG/L		
2944	DIBROMOCHLOROMETHANE	null	N		0	1.4 UG/L		